IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry Atwell DATE 5-22-05 PERMIT NO. 228

PHONE: Business _____ Home _____

LOCATION 15.2 E, TR, 2nd Rd in Rowan Co, CV: Kinson


No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (X)
Auto. Dishwasher	Yes (X)	No ( )
Auto. Wash. Machine	Yes (X)	No ( )
Site Suitable	Yes (X)	No ( )

Lot Area 20,000 Ft²

Character & Porosity of Soil Clay
Percolation Rate 3 gal/ft²/day
Topography Rolling
Depth to Water Table 4'
Rock or other impervious formations None obs.

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual (X)
Public ( )

Installed by Bostain

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clement

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Charles K. Bennett DATE 5-22-05

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold