HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Jeffery Jones OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 3-29-94
PROPOSED FACILITY: 3 BedRoom House
PROPERTY SIZE:
LOCATION OF SITE: W. Lewis Ferry Rd.
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY		
1	24-26% L	0-4"	l	gr	1:1 / vfr	.1942 WETNESS CONDITION	P.S.
		4"-45"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE	45"-↑
		45"-↑	saprolite			.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.3
2	24-26% L	0-3"	l	gr	1:1 / vfr	.1942 WETNESS CONDITION	P.S.
		3"-48"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE	NA
						.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.3
3	25-27% L	0-4"	l	gr	1:1 / vfr	.1942 WETNESS CONDITION	P.S
		4"-46"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE	46"-↑
		46"-↑	saprolite			.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.3
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) P.S SITE CLASSIFICATION (.1948): P.S. SITE LONG-TERM ACCEPTANCE RATE: .3 gpd/ft²
OTHER FACTORS(.1949): SYSTEM TYPE Pump to conventional
EVALUATED BY: Michael Dennis OTHER(S) PRESENT: J.C. Moore
COMMENTS: Recommend Interceptor Drain. Homeowner declined!

DRAFT