## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jack Secrest DATE 6/1/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Road 1369 at Lake _____


S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____
Garbage Disposal Unit Yes ( ) No ( )
Auto. Dishwasher Yes ( ) No ( )
Auto. Wash. Machine Yes ( ) No ( )
Site Suitable Yes ( ) No ( )
Lot Area _____

Character & Porosity of Soil _____
Percolation Rate Existing House
Topography _____
Depth to Water Table _____
Rock or other impervious formations _____



Plot of System

Size of Tank 1000 With Baffle Gals.
Nitrification Field:
No. of Lines 200' T+J Panels
Sq. Ft. _____ Linear Ft. _____
Depth of Stone in Lines _____
Water Supply: Individual ( )
Public ( )

Installed by Hahn Septic Tank Co

IMPROVEMENTS PERMIT BY _____

COMMENTS: 24' Panels used. This is an experimental sewage system. Installed due to high water table, soil conditions, available space etc.

CERTIFICATE OF COMPLETION BY Rollin W. Johnson R.S. & E. A. Stevenson DATE 6/1/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold