HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Ralph Woody OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 9-29-94
PROPOSED FACILITY: 3 Bedroom House
PROPERTY SIZE:
LOCATION OF SITE: Gray Rock Shoals S/D Lot #32
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring Pit ✓Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	30-31% L	0-6"	l	gr	fr	.1942 WETNES CONDITION	- S
		6"-24"	c	sbk	fi	1943/.1956 SAPROLITE	- @ 24" U
		24" +	saprolite	m	fi	.1944 RESTRICTIVE HORIZON	- NA
						.1948 PROFILE CLASSIFICATION	- U
						PROFILE LTAR	-
2	28-30% L	0-7"	l	gr	fr	1942 WETNES CONDITION	- S
		7"-30"	c	sbk	fi	1943/.1956 SAPROLITE	- 30" P.S.
		30" +	weathered Rock/ Saprolite	m	fi	1944 RESTRICTIVE HORIZON	- 30"
						.1948 PROFILE CLASSIFICATION	- P.S. LPP
						PROFILE LTAR	- .15
3	28-30% L	0-6"	l	gr	fr	.1942 WETNESS CONDITION	- S
		6"-36"	c	sbk	fi	.1943/.1956 SAPROLITE	- 36" P.S.
		36" +	saprolite	m	fi	.1944 RESTRICTIVE HORIZON	- 36"
						.1948 PROFILE CLASSIFICATION	- P.S. LPP
						PROFILE LTAR	- .15
4						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
5						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-

AVAILABLE SPACE (.1945) SITE CLASSIFICATION (.1948): SITE LONG-TERM ACCEPTANCE RATE:
OTHER FACTORS(.1946) SYSTEM TYPE
EVALUATED BY: J.C. Moore OTHER(S) PRESENT: Michael J. Dennis, [redacted] Doug Madison
COMMENTS:

DRAFT