DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #:
COUNTY: Pend.

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Walgorx APPLICANT: High Shoals Dev. Corp.
ADDRESS: 1805 Sabrina Rd Statesville APPLICATION DATE: 4 28 99 DATE EVALUATED: 5 10 99
PROPOSED FACILITY: 3BR Home PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.89
LOCATION OF SITE: Lot 21 Granstone Dr. Mapped (R) Both Sl. noted (R) PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other Gran. Rock (R) High Slopes 4th Lot on Left
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 35+	0-36	SBK C						PS .3
2	L 2-8%	0-38	SBK C	FI SS SO					PS .3
		38-48	SBK C/SAP	FR SS SO					
3	R 5-8% RT Rock	0-21	SBK C						PS .3
		21-50+	Sap/c mix						
		50+	WTHRD R/SAP						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1200 SQFT	Same
System Type(s)		
Site LTAR	.3	.3

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY: Joe Griffin
OTHER(S) PRESENT: