11129.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR DANIEL GAMBILL DATE 6-27-91. PERMIT NO. 844-B-38.

PHONE: Business _____ Home _____

LOCATION Hwy 70 W - 2 miles past White Oaks on left - Enter dev. & bear @ at forks - go to end. Ft. L. - 1st tract on R. S. R. No. _____

SUBDIVISION NAME WINDFOREST SECT. III. LOT NO. 38. SECTION OR BLOCK NO. _____

DOUBLEWIDE

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 5.11 acres.

Character & Porosity of Soil Prev. Suitable.

Percolation Rate 40 Min./Sq. Ft.

Topography 6-10% 15+

Depth to Water Table _____


Rock or other impervious formations scattered rock.

_____ Basement with Plumbing _____ Basement without Plumbing (✓) No Basement

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )



Plot of System

Installed by Keith Speece

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 6-27-91.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold