DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

LOT #26

OWNER: JENKINS APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: ___
PROPOSED FACILITY: 3 BR D.W. PROPOSED DESIGN FLOW (.1949): 360 GPD PROPERTY SIZE: ___
LOCATION OF SITE: ___ PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1		0-8	FILL		≥48"	≥48"	N/A	N/A	PS .35
		8-32	SC/C VNSBK	Fr SS SP					
		32-42	C/SAP WSBK	Fr SS SP					
		42-48	SAP (SC)						
2		0-6	SC GR	VFr NSNP	≥48"	≥48"	N/A	N/A	PS .35
		6-40	SC WSBK	Fr SS SP					
		40-48	SAP (SC)						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___