DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet
PROPERTY ID #
COUN

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Jenkins + Williams APPLICANT: Jenkins + Williams
ADDRESS: APPLICATION DATE: DATE EVALUATED: 7/12/04
PROPOSED FACILITY: 4BR MH/Crawl PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE:
LOCATION OF SITE: PROPERTY RECORDED: Yes
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Grace Meadows - Lot # 32

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	Linear	0-4	SCL wabk	Fr [illegible]					PS .3
		4-23	SC SBK	Fi S SE					
		23-34	CL Usap wSBK	Fr/Fi SS SP SE					
		34-48	Sap(s) LS	US NP NE					
2	Linear	0-4	SL g	Fr NS NP NE					PS .3
		4-30	SCL SBK	Fi/Fr SS SP SE					
		30-48	LS Usap wabk	Fr SS SP SE					
3	Linear	0-5	SL g	Fr NS NP NE					PS .3
		5-31	CL SBK	Fi/Fr SS SP SE					
		31-48	LS Usap wabk	Fr SS SP SE					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	25% Reduction Trench	Trench 25% Reduction
Site LTAR	.3	.3

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: