DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

PROPERTY I.D #. SHEET ___ OF ___
DATE: 8-29-95 / 8-30-95
COUNTY:

SOIL SITE EVALUATION FOR
ON-SITE WASTEWATER SYSTEM

APPLICA Chris Loudermilt
ADDRES
OWNER ___ AGENT: ___ PHONE:
APPLICATION DATE: ___ DATE EVALUATED 8-29-95 - 8-30-95
PROPOSED FACILITY: 2.45 acres
PROPERTY SIZE:

LOCATION OF SITE: Stacy Acres Lot # 8
WATER SUPPLY: On-site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS / SLOPE,%	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
(1)	6-8%	0-30"	C	sbk	I:1 / fr			.1942 Wetness Cond. - S
	L	30"-37"	C/sap.	sbk/m	I:1 / fr			.1943 Depth/.1956 Sapr. - NA
		38"	Rock					.1944 Restrictive Hori. - 38" P.S
								.1948 Profile Class. - P.S.
								Profile LTAR - .3
(2)	6-8%	0-40"	C	sbk	I:1 / fr			.1942 Wetness Cond. - S
	L	40"-48"	C/sap.	sbk/m	I:1 / fr			.1943 Depth/.1956 Sapr. - NA
								.1944 Restrictive Hori. - NA
								.1948 Profile Class. - P.S
								Profile LTAR - .3
(3)	6-8%	0-39"	C	sbk	I:1 / fr			.1942 Wetness Cond. - S
	L	39"-48"	C/sap.	sbk/m	I:1 / fr			.1943 Depth/.1956 Sapr. - NA
								.1944 Restrictive Hori. - NA
								.1948 Profile Class. - P.S
								Profile LTAR - .3
(4)	6-8%	0-36"	C	sbk	I:1 / fr			.1942 Wetness Cond. - S
	L	36"-	Rock					.1943 Depth/.1956 Sapr. - NA
								.1944 Restrictive Hori. - P.S 36"
								.1948 Profile Class. - P.S
								Profile LTAR - .3

AVAILABLE SPACE (.1945) S OTHER FACTORS (.1946) ___ SITECLASSIFICATION (.1948) P.S

SYSTEM TYPE conventional, gravity fed. LONG-TERM ACCEPTANCE RATE(S) .3gpd/ft²

EVALUATED BY: Michael J. Dennis OTHER(S) PRESENT: Brad Stallard / Chris Loudermilt

COMMENTS: