06970

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR JEFFERY WHITE DATE 3-17-88. PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Lewis Ferry Rd. off 21 Mts. Rd. go to Enfield Rd. - T.R. - 200 yards on left - Entrance - 2nd Drive to C. S. R. No. _____

SUBDIVISION NAME STACY ACRES DEV. LOT NO. 7 SECTION OR BLOCK NO. _____

DOUBLEWIDE

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 2.45 acres.

Character & Porosity of Soil Prop. Suitable
Percolation Rate 5 min/in.
Topography 2-10% Slope
Depth to Water Table 18+
Rock or other impervious formations none observed.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field: No. of Lines 3 300
Sq. Ft. 900 Linear Ft.
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by James Hudler

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Landscape over S.T. system for surface water control.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 3-17-88.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold