11340.

36860

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal Syst[illegible] -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR JACKIE LEE HENRY DATE 4-26-90 PERMIT NO. 90-5-A-2

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd. west 7-T.R.s. Eufola Mtge appear. two miles on left - Enter at 1st dirt road to left. S. R. No. _____

SUBDIVISION NAME STACY ACRES. LOT NO. 2 SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other DOUBLEWIDE

No. Bedrooms 3 No. Bathrooms 2 Character & Porosity of Soils Poor Suitable

Garbage Disposal Unit Yes ( ) No ( ) Percolation Rate 2-5 Min.

Auto. Dishwasher Yes ( ) No ( ) Topography 2-5%

Auto. Wash. Machine Yes ( ) No ( ) Depth to Water Table 3ft+

Site Suitable Yes ( ) No ( ) Rock or other impervious formations Not observed.

Lot Area 2.16 acres.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

Size of Tank 1000 Gals.

Nitrification Field:


No. of Lines 2

Sq. Ft. 400 Lines Ft. 300

Depth of Stone in Liner 12

Water Supply: Individual ( )

Public ( )



Plot of System

Installed by Jones Hudler

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown & J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 4-26-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold