DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #:
COUNTY: Tick H

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Pearl Gibbs APPLICANT:
ADDRESS: P. Box 706 Clarkmont NC APPLICATION DATE: 4 28 99 DATE EVALUATED: 5-14-99
PROPOSED FACILITY: 3BR SFM H PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 6.4 Sac
LOCATION OF SITE: E Lewis Ferry From Old NC Rd on Right 2nd house Past Bridge PROPERTY RECORDED:
Rock Rapids Rd
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 0-2%	0-18	SBK SC	FR	Red/Yellow				PS .3
		18-48	SBK C/SBC SiCL/SiC Red	F, FR SS SP SEXP					
2	L 0-2%	0-12	SBK SC	FR	Red				PS .3
		12-48	SBK C	F, SS SP SEXP					
3	S 2-3%	0-12	SBK C	F SS SP SEXP					PS .3
		12-48	SBK C SC	FR F, SS SEXP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space	1200 Sq Ft	1200 Sq Ft
System Type(s)	Conv Capt	Conv/Resp Rdc
Site LTAR	.3	3

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: C. Foster
OTHER(S) PRESENT: