DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

COUNTY: Tidell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Bill Coley OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 6-27-94
PROPOSED FACILITY: 3 Bedroom DW MH
PROPERTY SIZE: ≈ 1.0 acres.
LOCATION OF SITE: Lewis Ferry Rd. 2nd lot on L past Lamb Rd.
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY		
1	4-6% L	0-17"	cl	gr	vfr	.1942 WETNES CONDITION	S
		17"-42"	c	Abk	fr	.1943/.1956 SAPROLITE	42" P.S.
		42"-48"	c/sap mix	Abk/m	fr	.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.3
2	5-7% L	0-12"	cl	gr	vfr	.1942 WETNES CONDITION Relic mottling	P.S.
		12"-48"	c	sbk	fr	.1943/.1956 SAPROLITE	NA
						.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.35
3	4-6% L	0-8"	cl	gr	vfr	.1942 WETNESS CONDITION	S
		8"-42"	c	Abk	fr	.1943/.1956 SAPROLITE	42" P.S.
		42"-48"	c/sap mix	Abk/m	fr	.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.3
4	3-5% L	0-5"	cl	gr	vfr	.1942 WETNESS CONDITION Relic mottling	P.S.
		5"-44"	c	Abk	fi	.1943/.1956 SAPROLITE	44" P.S.
		44"-48"	c/sap mix	Abk/m	fi	.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.3
5	4-6% L	0-10"	cl	gr	vfr	.1942 WETNESS CONDITION	S
		10"-48"	c	Sbk	fr	.1943/.1956 SAPROLITE	NA
						.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.3

AVAILABLE SPACE (.1945) SITE CLASSIFICATION (.1948): SITE LONG-TERM ACCEPTANCE RATE:
OTHER FACTORS(.1946) SYSTEM TYPE
EVALUATED BY: OTHER(S) PRESENT: Info on next page
COMMENTS:

DRAFT