12245.

38751

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR EDWIN M. CLARK DATE 12-7-90 PERMIT NO. IC-A-18

PHONE: Business _____ Home _____

LOCATION Hwy 70 W-T.L. on Old Mt. Rd.-T.R. on Lewis Ferry Rd.-gravel rd. Enfield Rd. 1st gravel rd. one mile on left-Dan Lewis Back off rd. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 12.93 acres

Character & Porosity of Soil Gravel Suitable

Percolation Rate Less than 60 min.

Topography 2-6% slope

Depth to Water Table 12+

Rock or other impervious formations None observed.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"


Water Supply: Individual (✓)
Public ( )

Ben Grant

Installed by West Lincoln Grading

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____



Plot of System

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Drop boxes used.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 12-7-90.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold