IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 79584 PIN# 4702 73 7267 DATE 3 23 99

OWNER OR CONTRACTOR MARK EVERHART PHONE: Business 704 630 9266 Home

ADDRESS c/o 3835 Statesville Blvd Salisbury NC

LOCATION Lot 39 Lansdowne off Eufola Rd

SUBDIVISION Lansdowne BLOCK / SECTION LOT 39 LOT AREA 1.04 Ac SITE CLASS PS DESIGN FLOW 360 L.T.A.R. .03

Septic Tank: 1000 Gallons: STB 794 Date 11-22-98 ☑ New System ☐ Repair System Type: I. (II) III. IV. V. VI

Pump Tank: Gallons: PT Date System Description: Conv. Gravity

Pump Make: Model Serial No. Repair System Description: Pump 25% Reduction

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400 Maintenance Agreement Required: ☐ Yes ☑ No

No Lines 5 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth 12"

☐ House/Mod. Home ☑ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Bathrooms 2½ No. Employees

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☐ Community

Comments/Conditions: Property Line 375 Ft

Install lines on Contour

*Landscape To divert Surface H_2O from System

INITIAL SITE SKETCH

10' 5 Drop Boxes Surface Diversion Berm*

3x16 3x16 3x16 3x16 3x16

9'10" 9'10"

46' Home 22' Car Port

98'

25 Ft

Divert Surface Drain To Run Property Line

Lot 38

H_2O

Drive

Comments/Conditions: Tank Slightly turned

Pump

Repair 25% Reduction

AS BUILT SKETCH

269 Ft

Installed as shown

Lot 40

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Hank Brewer date

Improvement Permit by: Joe Potter date 3 23 99

Authorization to Construct by: Joe Potter date 3 23 99

Installed by: Dellinger Grading

Operation Permit by: Mat Cosper date 5-4-99

Existing System Inspection by: date

HEALTH DEPT. COPY WHITE OWNER COPY (FINAL) YELLOW OWNER COPY (INITIAL) PINK