SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: JEFFREY EADES OWNER: ~~AGENT~~: PHONE: 528-9391
ADDRESS: 159 ANGER LANE APPLICATION DATE: 3/24/97 DATE EVALUATED: 4/15/97
SNL, NC PROPOSED FACILITY: 3BR S/W MH
PROPERTY SIZE: 1+ ACRE
LOCATION OF SITE: 121 LAMB ROAD
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ✓ Cu

PROFILE #	.1940 LANDSCP POSITN	HORIZON DEPTH (IN)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1949/ 1956 SAPRLT CLASS.	HORIZ LTA
	H 18%	0-36"	SL / GR	1:1 / VFR	—	—	PS	-	0.4
		36-48	SiC / WSBK	1:1 / FR					
2	L 25%	0-32"	GRAVELLY SL / GR	1:1 / VFR	—	—	PS	-	0.4
		32-48"	SiC / WSBK	1:1 FR					
3	N 24%	0-30	GRAVELLY SL / GR	1:1 / VFR	—	—	PS	—	0.4
		30-48	SiC / WSBK	1:1 / FR					
4									
5									

AVAILABLE SPACE (.1945): PS SITE CLASSIFICATION (.1946): PS SITE LONG-TERM ACCEPTANCE RATE: 0.4
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: VIRGINIA EADES ET. AL
COMMENTS: I - CHAMBERED, R - PPBPS