IREDELL COUNTY HEALTH DEPARTMENT

Phone 1164

County Building — Statesville, N. C.

PERMIT TO INSTALL SEPTIC TANK

Permit No. _____ Permit Date July 6 1950

Owner O. C. Shavis Address Troutman

Tenant _____ Address _____

Installed by A. K. Lowery Address Mooresville

Location of Property _____

Kind of Tank Poured Capacity 600 Length of trench 200 ft


NOTIFY HEALTH DEPARTMENT AT LEAST EIGHT HOURS BEFORE TANK IS TO BE INSPECTED

There must be at least 200 feet of tile in line, with cinder pit at end.

Final Inspection July 6 1950 Approved (✓) Disapproved ( )

Remarks: _____

First five feet of line from outlet should be of cast iron soil pipe.



James E. Brown
Sanitarian.

Sketch of tank and line showing distance from dwelling and well on subject property and on adjoining property.