WASTEWATER SECTION

COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Rita Bearly

S: _____ APPLICANT: _____

APPLICATION DATE: _____ DATE EVALUATED: _____

ED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____

ON OF SITE: _____ PROPERTY RECORDED: _____

SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____

TION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut

WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
Linear H90	0to6	L	GV					
	6to48	C	Firm	Chroma 4	48"+	N/A		125
Linear S9%	0to6	L	GV					
	6to48	C	Firm		48"+	N/A		125

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
ilable Space (.1945)		

OTHER FACTORS (.1946): _____

SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____