DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #:
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: Kings Forest
ADDRESS: 5551 Monroe Rd Charlotte APPLICATION DATE: 5-28-99 DATE EVALUATED: 7-8-99
PROPOSED FACILITY: 3BR Rm DW PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .75
LOCATION OF SITE: Lot 35 Lakeshore Barbary Rd on Right off Eufola PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 2-3%	0-9	Plow Gr Sc						PS .3
		9-32	SBK C	FR SS SCPL					
		32-48	SBK C w/Rel	FR					
		48+	SAP						
2	L 3-5%	0-9	Plow Gr Sc						PS .3
		~~9-48~~							
		9-30	SBK C	FR					
		30-48	SBK C w/Rel	FR					
3	L CL 3-5%	0-18	Gr Sc						PS .3
		18-48	SBK C						
		48+	SBK C w/Rel	FR	Mottled				
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	120	Same
System Type(s)		
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: J.C. Potts
OTHER(S) PRESENT: _____