DEPARTMENT OF ENVIRONMENT, HEALTH AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: Stanly

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Bill Powell — APPLICANT: Old Town Mobile Home
ADDRESS: RT 2 Box 205L Albemarle NC 28001 — APPLICATION DATE: 6 10 99 — DATE EVALUATED: 6 1999
PROPOSED FACILITY: 3 Bdrm DW — PROPOSED DESIGN FLOW (.1949): 360 — PROPERTY SIZE: 1.06
LOCATION OF SITE: Lot 22 Lansdowne — PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
1	L 15%	0-48	SBK C	F, SS SP SAP					PS 1.3
2	L 10-15%	0-12	SBK C	F,					PS 1.3
		12-33	SBK C w/ SAP R.C.	F,					
		33+	SAP/C mix						
3	L 10	0-12	SBK C						PS .3
		12-33	SBK C w/ SAP	F,					
		33+	SAP						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1200 Sq Ft	Same
System Type(s)	Conv Gravity	25% Red Conv.
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: JC Potter
OTHER(S) PRESENT: ___