DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of ___
PROPERTY ID #: ___
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Freedom Haynes APPLICANT: Jason Wood
ADDRESS: 1018 Charlotte Hwy Statesville NC APPLICATION DATE: 5-25-99 DATE EVALUATED: 6-2-99
PROPOSED FACILITY: 3 Bdrm DW PROPOSED DESIGN FLOW (.1949): ___ PROPERTY SIZE: 1.65 Ac
LOCATION OF SITE: Lot 19 Lansdowne Entrance Rd To Bar on the Left PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 2-3%	0-9	GR PLW C	VFR					PS .3
		9-24	SBK C	FR SS SP SLPP					
		24-49	SBK C W/RL	FR SS SP SLPP					
2	L 5%	0-9	Plow GR C	VFR					PS .3
		9-26	SBK C	FR-FR SS SP SLPP					
		26-49	SBK C W/RL	FR-FR SS SLPP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1000 Sq Ft	Same
System Type(s)	Conv Gravity	25% Reduction
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: JC Potter
OTHER(S) PRESENT: ___