DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: ____
COUNTY: ____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: ____ APPLICANT: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 2-6-01
PROPOSED FACILITY: ____ PROPOSED DESIGN FLOW (.1949): ____ PROPERTY SIZE: ____
LOCATION OF SITE: Lot 12 Shenandoah PROPERTY RECORDED: ____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941T STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-10	gr brn sl/sdl fr ssp						IS .3
		10-39	sab yr r/c/cl fr sp-ss sp scp						
		39-49	wk ab/sbk yr cl/L few-common fi sp fi sp						
2		0-10	gr brn sl/sdl fr						IS .3
		10-33	sab pcl/L fr						
		33-50	wk f sbk yr L common fi sp fi sp						
3		0-11	gr brn sl/sdl fr ssp						IS .3
		11-32	sab brn pcl/L fr sp-ss sp scp						
		32-54	wk sbk pcl/L common fi sp fi ssp						
4		0-11	gr brn sl/sdl fr ssp						IS .3
		11-41	sab yel cl fr sp-ss sp scp						
		41-48	wk sbk pcl/L fr ssp fi sp						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): ____
EVALUATED BY: ____
OTHER(S) PRESENT: ____