DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: ____
COUNTY: ____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: ____ APPLICANT: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 2-6-01
PROPOSED FACILITY: ____ PROPOSED DESIGN FLOW (.1949): ____ PROPERTY SIZE: ____
LOCATION OF SITE: lot 11 Shenandoah PROPERTY RECORDED: ____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-10	gr brnsl/sd fr						PS .3+
		10-52	wk sbk rbrnck fsl/sl sp	fr- ss/sp/sk/p					
2		0-10	gr brnsl/sd fr ss/sp/sk/p						PS .3
		10-40	sbk rc/cl fr ss/sp/sk/p						
		40-52	wk sbk/massive cl/c fi ss/sp/sk/p fsl-						
3		0-12	gr/sbk brnsl/sl cl/c fr						PS .3 @ 36"
		12-36	sbk rc/cl fr ss/sp/sk/p fsl/sicl/sp. common rock						
		36-50	soil/sap/rock mix						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): ____
EVALUATED BY: ____
OTHER(S) PRESENT: ____