DEPARTMENT OF ENVIRONMENT, HEALTH AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #:
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Barbara Seymore APPLICANT:
ADDRESS: 230 E Broad St Statesville APPLICATION DATE: 6.2.99 DATE EVALUATED: 6.12.99
PROPOSED FACILITY: 3Bdrm DW PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .76
LOCATION OF SITE: Lot 3 Lansdowne off Eufola from Old NT Rd PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 3%	0 9	Plow GR	VFR					PS .3
		9.48	SBK C	FI VFI SS SP SEVP					
		48	Relic inclusions Clay						
2	L 3%	0.9	Plow GR	VFR					PS .3
		9.48	SBK C	FI VFI SS SP SEVP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1200sq Ft	5[illegible]
System Type(s)	25% Reduction	Sand/Pump
Site LTAR	.3	.3

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Joe Sotter
OTHER(S) PRESENT: