DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #:
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Herman Hunter APPLICANT:
ADDRESS: 3700 Avalon Ah Charlotte N/C APPLICATION DATE: 5.10.99 DATE EVALUATED: 5 24 99
PROPOSED FACILITY: PROPOSED DESIGN FLOW (.1949): PROPERTY SIZE: 37 Ac
LOCATION OF SITE: Lot 7 Lansdowne off Eufola Rd @ Barbary circle PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 3.5%	0-19	Plow GR C						PS .3
		19-36	SBK C	F SS SP SPO					
		36-52	SBK C w/ SAP Fragments	F FR SS SOAP					
2	L 2.3%	0-22	GR C						PS .3
		22-36	SBK C	F SS SP SLIP					
		36-48	SBK C w/ SAP Fragments	FR					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1200 Sq Ft	Same
System Type(s)	25% Reduction	25% Reduction
Site LTAR	.3	.3

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: [illegible]
OTHER(S) PRESENT: