DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: ____
COUNTY: ____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: ____ APPLICANT: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 2-5-07
PROPOSED FACILITY: ____ PROPOSED DESIGN FLOW (.1949): ____ PROPERTY SIZE: ____
LOCATION OF SITE: Lot 5 Shenandoah PROPERTY RECORDED: ____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed 24 bedrooms

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-8	gr bnr sl/scl fr sssp		few ind sap 17-24" common ind sap 24-36				PS 1.3 @ 24"
		8-36	SAB R/cl fr-fi sssp SEXP						
		36-51	CL/SAP mix few ind WR fi sssp		prev sap Visible sl/sap horizon				
2		0-11	gr bnr sl/scl fr sssp						PS 1.3 @ 40"
		11-40	SAB R/cl fr sssp few ind sap						
		40-61	marine bnr cl/sap/WR mix fi sssp - prev sap						
3		0-11	gr bnr sl/scl fr						PS .3
		11-28	SAB bnr R/cl fr sssp sssp SEXP						
		28-48	mix sap/ma R/cl fi sssp						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): ____
EVALUATED BY: ____
OTHER(S) PRESENT: ____