IVISION OF ENVIRONMENTAL HEALTH
N-SITE WASTEWATER SECTION

PROPERTY ID #: ____
COUNTY: ____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

WNER: ____ APPLICANT: ____
DDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: ____
ROPOSED FACILITY: ____ PROPOSED DESIGN FLOW (.1949): ____ PROPERTY SIZE: ____
OCATION OF SITE: lot 3 Shenandoah PROPERTY RECORDED: ____
VATER SUPPLY: ❑ Private ❑ Public ❑ Well ❑ Spring ❑ Other ____
VALUATION METHOD: ❑ Auger Boring ❑ Pit ❑ Cut
YPE OF WASTEWATER: ❑ Sewage ❑ Industrial Process ❑ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-10	gr brn sl/scl fr sssp						PS .25-.3
		10-24	wt sab brn scl/cl fr ss sp						
		24-46	wt sab brn lcs/scl/cl fr ss sp		ssab				
		46-64	wt sab brn cl fr ss sp						
2		0-7	gr brn cl/sicl fr ssp						PS .3
		7-55	wt sab rd/cl fr ssp						
3		0-5	granular expected brn sl/scl fr ssp						PS .3
		5-42	sab rd/cl fr ss sp						
		42-57	wt sab brn cl fr ss sp						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): ____
EVALUATED BY: ____
OTHER(S) PRESENT: ____