IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Benny Upright DATE 1-7-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd to Rd #1333. T.R. Go approx. 2 miles House on Rt just before Upright's Garage S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


30' ACCESS BLDG 48'

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(✓)	Character & Porosity of Soil: Red Clay
Auto. Dishwasher	Yes	( )	No	(✓)	Percolation Rate:
Auto. Wash. Machine	Yes	(✓)	No	( )	Topography: Slope to creek
Site Suitable	Yes	(✓)	No	( )	Depth to Water Table: Low
					Rock or other impervious formations: None

Lot Area 1 Acre

~100' TO HOUSE



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )
From house next door

Installed by Henry Sigmon

Location of the proposed 30'x48' ACCESS. BLDG. addition does not appear to impact the existing on-site septic system.**NOTE: KEEP MIN. 5' FROM SYSTEM

R. STEVE HENDRICK REHS
Date: 11-21-2012
ICHD-Environmental Health Division

IMPROVEMENTS PERMIT BY _____

COMMENTS: Installed in Wet Weather!

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 1-7-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold