DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of 11
PROPERTY ID #: 4702872027
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Heritage Building
ADDRESS: Eufola Rd.
PROPOSED FACILITY: 4 BR
PROPOSED DESIGN FLOW (.1949): 480
LOCATION OF SITE: Eufola
APPLICATION DATE 3-7-13
DATE EVALUATED: 4-1-13
PROPERTY SIZE: 7.542
PROPERTY RECORDED: yes
WATER SUPPLY: • Private • Public • Well • Spring • Other
EVALUATION METHOD: Auger Boring • Pit • Cut
TYPE OF WASTEWATER: Sewage • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	14 LS	0-17	C SBK	SS SP	n/a	48"	n/a	n/a	.3 PS
		17-48	CL SBK	SS SP					
2	14 LS	0-14	C SBK	SS SP	n/a	48"	n/a	n/a	.3 PS
		14-48	CL SBK	SS SP					
3	LS 14	0-19	C SBK	SS SP	n/a	48"	n/a	n/a	.3 PS
		19-48	CL SBK	SS SP					
4	LS 14	0-16	C SBK	SS SP	n/a	48"	n/a	n/a	.3 PS
		16-48	CL SBK	SS SP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	III	III
Site LTAR	.3	.3

OTHER FACTORS (.1946): none
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: James Stewart
OTHER(S) PRESENT: none

COMMENTS: