ON-SITE WASTEWATER SECTION

COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: CLAUDETTE BALLARD APPLICANT: SAME

ADDRESS: HICKORY DR, STATESVILLE APPLICATION DATE: _____ DATE EVALUATED: 12-8-00

PROPOSED FACILITY: 2BR S/W MH PROPOSED DESIGN FLOW (.1949): 240 PROPERTY SIZE: _____

LOCATION OF SITE: JEFFERSON LANDING #10 PROPERTY RECORDED: _____

WATER SUPPLY: ~~☐ Private~~ ☐ Public ☐ Well ☐ Spring ☐ Other _____

EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut

TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	(.1940) LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH IN.	SOIL MORPHOLOGY (.1941) (.1941) STRUCTURE/ TEXTURE	(.1941) CONSISTENCE/ MOIST/WET	OTHER PROFILE FACTORS (.1942) SOIL WETNESS/ COLOR	(.1943) SOIL DEPTH	(.1956) SAPRO CLASS	(.1944) RESTR HORIZ	PROFIL CLASS & LTAR
1	N 20%	0-18	GR SBK / SC	FR / SP/SEXP					PS 0.3
		18-36	WARK SBK / SC	FR / SP/SEXP	MOTTLES	PS			
		36	— ROCK — COULDN'T AUGER						
					B1 — SUBSURFACE INTERCEPT DRAINAGE DITCH REQUIRED				
2			SEE SOIL SHEET FOR LOT #11						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): NONE

SITE CLASSIFICATION (.1948): _____

EVALUATED BY: S. HENDRICK BILL JOHNSON

OTHER(S) PRESENT: CLAUDETTE BALLARD