DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___

COUNTY: Person

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: SAM HEATON APPLICANT: CANDETTE BALLARD
ADDRESS: 110 HAWK ROAD STVL APPLICATION DATE: 8-4-00 DATE EVALUATED: 9-2-00
PROPOSED FACILITY: 3BR D/W MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 0.613 AC
LOCATION OF SITE: JEFFERSON LANDING # 6 PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	L 12%	0-4	MMGR / CL	FR / SEXP			PS		PS 0.25
		4-29	MMSBK / C	FI SS/P/SEXP					
		29-37	MMSBK / C	FI SS/P/SEXP					
		37-48	CL/SAPROLITE MIX						
2	L 10%	0-5	MMGR / CL	FR / SEXP			PS		PS 0.25
		5-25	MM ABK MMSBK / C	FI SS/P SEXP					
		25-40	MMSBK / C	FI SS/P SEXP					
		40-48	CL/SAPROLITE						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	III	IV
Site LTAR	0.25	0.45

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS

EVALUATED BY: S. HEDRICK
OTHER(S) PRESENT: LORNE COOK, BILL JOHNSON