HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Sunwood OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE: Key acres 4
WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cut

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	linear 8%	0to48	C SBK	SEAP Fi	PS	PS	PS	PS	.3
2	linear 10%	0to48	C SBK	SEAP Fi	PS	PS	PS	PS	.3
3									
4									
5									

AVAILABLE SPACE (.1945): SITE CLASSIFICATION (.1948): SITE LONG-TERM ACCEPTANCE RATE: 1.3
EVALUATED BY: E.C. Moore OTHER(S) PRESENT:
COMMENTS: Perry Jenkins

00242S