HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Sunwood Builders OWNER: AGENT: PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____
PROPERTY SIZE: _____
LOCATION OF SITE: Lot 11 + 8
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring + Pit ___ Cut ___
+ Pits

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	15 90	0 to 4	L GR		PS	Rock Sap 36	PS	PS	.3
		4 to 20	C SBK	S EAP Fi					
		20 to 36	Clay Sap.						
		36"+	Rock + Sap						
2	12 90	0 to 4	L GR		PS	Rock Sap 36	PS	PS	.3
		4 to 24	C SBK	S EAP Fi					
		24 to 36	Clay Sap						
		36"+	ROCK + Sap						
3	12 90	0 to 6	L GR		PS	Rock Sap. 40	PS	PS	.3
		6 to 30	C SBK	S EAP Fi					
		30 to 40	Clay Sap						
		40"+	Rock Sap						
4	12 90	0 to 6	L			U 18"		U	
		6 to 18	C						
		18"	Rock						
5	12 90	0 to 6	L			U 18"		U	
		6 to 18	C						
		18"	Rock						

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): _____ SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: J.C. Moore OTHER(S) PRESENT: _____
COMMENTS: _____

0 0 2 3 9 3