PARTMENT OF ENVIRONMENT,
EALTH, & NATURAL RESOURCES
VISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

PLICANT: John Blansett OWNER: AGENT: PHONE: ___
DDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: ___
PROPOSED FACILITY: ___
PROPERTY SIZE: ___
CATION OF SITE: ___
ATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	linear 10%	0 to 18	C SBK	SEAP SS SP					.3
		18 to 36	clay Sap						
		36"+	Rock + Sap						
2	linear 12%	0 to 20	C SBK	SEAP SS SP					.3
		20 to 37	clay Sap						
		37"+	Rock Sap						
3									
4									
5									

SUITABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): ___ SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: J. C. Moore OTHER(S) PRESENT: ___
COMMENTS: ___

0039