12936.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR JOHN R. JOHNSON DATE 10-1-91. PERMIT NO. 8H-4-A- 35 36 37.

PHONE: Business _____ Home _____

LOCATION Hwy 70W - 2 miles past White Oaks on left. - Enter dev. - bear @ tanks. go around to Cul-de-sac on R up on hill.


SUBDIVISION NAME WINDFOREST DEV. LOT NO. 35/36/37 SECTION OR BLOCK NO. _____ S. R. No. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Prev. Suitable.
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	4 gal./sq. ft.
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	6-15%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
Lot Area 5.3 acres.			Rock or other impervious formations	scattered rock.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12

Water Supply: Individual (✓)
Public ( )

Installed by Charlie Bryce

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 10-1-91.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold