07880

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jimmy LACKEY DATE 4-14-88 PERMIT NO.

PHONE: Business Home

LOCATION Hwy 64-West appx. 1.5 miles past Little Oak on left on Mr. Ivey's Dr. 1st Drive on L.

S. R. No.

SUBDIVISION NAME PINEFOREST DEV. LOT NO. 8 SECTION OR BLOCK NO.

Home ( ) Mobile Home (✓) Business ( ) Other


No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Sandy Suitable.
Percolation Rate 2 28 Lg. ft.
Topography 2 to 8 %
Depth to Water Table 72"
Rock or other impervious formations scattered rock.

Lot Area 1.82 acres.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Lines @ 240
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Dennis Hallibes

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 4-14-88.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold