13225.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR ROGER E. ELLIOTT DATE 8-26-91. PERMIT NO. SH-4-B-19.

PHONE: Business _____ Home _____

LOCATION Hwy 70W - 2 miles past White Oaks - T.L. into dev. - 3rd lot on left. S. R. No. _____

SUBDIVISION NAME WINDFOREST DEV. LOT NO. 19. SECTION OR BLOCK NO. _____

House ( ) Mobile Home (4) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (4)
Auto. Dishwasher Yes ( ) No (4)
Auto. Wash. Machine Yes (4) No ( )
Site Suitable Yes (4) No ( )

Character & Porosity of Soil Prev. Suitable.
Percolation Rate _____ Gal./Sq. Ft.
Topography 2-8%
Depth to Water Table 10+
Rock or other impervious formations scattered rock.

Lot Area .95 acres.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (4)
Public ( )

Installed by Wes Lytton

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 8-26-96

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold