DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Mary Post
APPLICANT: ___
ADDRESS: ___
APPLICATION DATE: ___
DATE EVALUATED: 6-10-02
PROPOSED FACILITY: Reburn SFR
PROPOSED DESIGN FLOW (.1949): 360 gpd
PROPERTY SIZE: ___
LOCATION OF SITE: Lot 25 Shaw Mines
PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1950 SAPRO CLASS	1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
1	L	0-18	gr brn sl						PS .25 @ 43"
		18-36	f-w sab rbrn scl/sicl	fr sp sp					
		36-48	sab ry c/cl	sp-vsp mod/4"+					
			w/ mica & vein q						
2	L	0-18	gr brn sl	vfr sp vp					PS .2 @ <32"
		18-27	sab brn cl	fr ss sp vp					
		27-32	sab yb/gl cl	fr ss sp vp few C					
		32-40	f-m sab brn/gy	sc 1-mod sp-vsp vp/ss sp vp					
3	L	0-10	gr brn sl/scl gr						PS .3
		10-20	sab, rc	fi sp ste vp					
		20-48	m-w sab brn/rb cl	fr ss sp/ss vp					
			w/ mod sap fbrn/bne						
4	L	0-48	gr sl, sab rc/cl/scl	fr					PS .3

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
*System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___

00316