E WASTEWATER SECTION

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

ER: Patricia Tenter APPLICANT: _____

ESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____

OSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____

TION OF SITE: _____ PROPERTY RECORDED: _____

ER SUPPLY: ❑ Private ❑ Public ❑ Well ❑ Spring ❑ Other _____

UATION METHOD: ❑ Auger Boring ❑ Pit ❑ Cut

OF WASTEWATER: ❑ Sewage ❑ Industrial Process ❑ Mixed

.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
Ridge 10%	0to12	C						135 PS
	12to36	SCL						
	36to48	SCL + Sap						
Ridge 6%	0to18	C						135 PS
	18to36	SCL						
	36to48	SCL + Sap						
Linear 15	0to18	Rock + clay						Unsuitable
	18"+	Hearing Rock						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		

OTHER FACTORS (.1946): _____

SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____

OTHER(S) PRESENT: _____