ENVIRONMENTAL HEALTH AND NATURAL RESOURCES
ENVIRONMENTAL HEALTH
STEWATER SECTION

Sheet 1 of 2
PROPERTY ID #:
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

NER: Peeko Inc APPLICATION DATE
DRESS:
DATE EVALUATED: 1-7-99
DPOSED FACILITY: house PROPOSED DESIGN FLOW (.1949): 360 gpd PROPERTY SIZE: 138 X 205
CATION OF SITE: Lot # 37 PROPERTY RECORDED:
TER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other
ALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
PE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	4-5% LS	0-2/3	fill			* 25/26 minus fill			.1
		3-5	cl gr	fr					
		5-15	c sbk	fi					
		15-24/29	c sbk/eap	fi					
		24/29+	WR/sed	fi-vfi					
2	LS	0-4/5	fill			*44" minus fill			.3
		5-10	cl gr	fr					
		10-30/31	c sbk	fi					
		30/31-49/50	cl/c sbk/eap	fi					
		44/50+	cl map	fi					
3	LS	0-3	fill			* 29/30 minus fill			.125
		3-8	cl gr	fr					
		8-16	c sbk	fi					
		16-21/40	c/cl sbk/eap	fi					
		21/40-48	WR/eap						
4	LS 5-6	0-3	fill			* 28" minus fill			.125
		3-8	cl gr	fr					
		8-27	c sbk	fi					
		27-42	c/cl sbk/eap	fi					
		42"+	WR/eap						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
vailable Space (.1945)	PS	PS
ystem Type(s)	25% red	LPP
te LTAR	.3	.125-.1

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Joe Lynn
OTHER(S) PRESENT: Jack Moore, Jeff Morgan