12041.

58312

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR LINDA J. PRIVETTE DATE 11-21-90 PERMIT NO 8H-A-134

PHONE: Business _____ Home _____

LOCATION Hwy 70 W- past Tuttle Store - go approx. 2 miles past Bethel Church on left. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Permeability of Soil	Poor Suitable.
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	60 min/in
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Hilly
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'
Lot Area 3 Acres.			Rock or other impervious formations	None observed.

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓



Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 720 Linear Ft. 240

Depth of Stone in Lines 24

Water Supply: Individual ( )

Public (✓)

Installed by Tommy Frye

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Part of System:

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 12-1-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold