IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 206253

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4703218067

APPLICANT: Abee's Clearing & Grading APPLICANT ADDRESS: 2381 US Hwy 64 West

SITE ADDRESS: 198 Starr Ln. PHONE: 704-239-3693 ALT. PHONE: N/A

SITE DIRECTIONS: Hwy 70W TL Morrow Farm Rd TR Starr Ln.


SUBDIVISION: N/A SECTION: N/A LOT # N/A LOT AREA: 2.56 acres DESIGN FLOW: 360gpd L.T.A.R.: 0.25

Septic Tank	1000 (gal)	STB	760-1000	Date	12-20	☑ New System	☐ Repair	☐ Expansion	System Type: I II (III) IV V VI	☐ Residence	No. Bedrooms 3
Pump Tank	(gal)	PT		Date		System Description:	25% Reduction			☐ Business	No. Persons 6
Pump Make		Model		Serial #		Repair System Description:	25% Reduction			☐ Other	No. Employees
# Nitrification Fields	1	# Lines	3	Linear Ft:	360	Maintenance Agreement Required:	☐ YES	☑ NO		☐ Slab	☑ Crawl Space
Trench Width	36"	Max. Trench Bottom Depth	36"	Gravel Depth	N/A		☑ GRAVITY	☐ PRESSURE		☐ Basement w/plumbing	☐ Basement w/o plumbing


Water Supply: ☑ Private ☐ Public ☐ Community

Comments / Conditions: Install a 25% Reduction system on contour with serial distribution. * Install a surface diversion berm @ location shown below **

INITIAL SITE SKETCH



FINAL SKETCH



Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☑ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT–not to exceed 60 mo.*

Owner / Applicant Signature: Jerral Abee Date: 1/21/15 Installed by: Groundbreakers

IMPROVEMENT PERMIT by: Justin Henderson Date: 1-14-15 OPERATION PERMIT by: Justin Henderson Date: 4-28-15

AUTHORIZATION TO CONSTRUCT by: Justin Henderson Date: 1-14-15 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK