IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR E.L. Neal DATE 6-3-25 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64 W. 20 W, T.L on Rd 1371 near Tom Wilsons Store, T.R. at 1st Drive Trailer on RT S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 2 acres

Character & Porosity of Soil Cecil Clay
Percolation Rate _____
Topography Slight Slope
Depth to Water Table Low
Rock or other impervious formations none noted



Plot of System

Size of Tank 1,000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Eddie Yountz

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 6-3-25

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold