IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

Rev. Robert Sprinkle
OWNER OR CONTRACTOR Providence Church DATE 3/10/75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64 W bd. - Trailer Behind Church, located across from Tom Wilsons Store S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 1 Acre

Character & Porosity of Soil Suitable
Percolation Rate _____
Topography slight slope
Depth to Water Table _____
Rock or other impervious formations none noted



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 208
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by S+H Pools

IMPROVEMENTS PERMIT BY _____

COMMENTS: System installed in inclimate weather, NOT enough drop from tank to system

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 3/10/75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold