IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Earnest Beaver DATE 11-9-73 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64-70 W. T.R. on Rd # 1506 at Tom Wilsons Store T.R. on Dirt Road at Curve - Last Tank in Park S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area Acreage

Character & Porosity of Soil _____
Percolation Rate Addition to
Topography Existing System
Depth to Water Table _____
Rock or other impervious formations _____



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 450 Linear Ft. 180
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Harlan Lackey
This installation for 2 Trailers only

IMPROVEMENTS PERMIT BY _____

COMMENTS: This is an addition to an existing system in order to conform to regulations for 2 Trailers - Original installation of 225' was inspected by Mr R.W. Johnson on 4-5-72

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 11-9-73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold