04934

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR JAMES ASHLEY DATE 8-8-86 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Mack Hall Rd - off Bentak Rd - MH behind Pitts house on left. _____ S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 200' x 225'

Character & Porosity of Soil Sandy Loam

Percolation Rate 1-30 min per ft

Topography Slight slope

Depth to Water Table 60"+

Rock or other impervious formations None encountered

( ) Basement with Plumbing ( ) Basement without Plumbing (✓) No Basement

Size of Tank 1000 Gals.

Nitrification Field: 3


No. of Lines

Sq. Ft. 720 Linear Ft. 240

Depth of Stone in Lines 12"

Water Supply Individual (✓)

Public ( )



Plot of System

Installed by James Hartless

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

REMARKS _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 8-8-86

SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

VOID if any unauthorized changes are made in installation of system and or if any false information is supplied in making Improvement Permit

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold