03994

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR TONY W. LACKEY DATE 1-3-86 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION MOCK MILL RUN - 2nd entrance at cul-de-sac on (E).

SUBDIVISION NAME MOCK MILL RUN LOT NO. 15 + 1/2 OF 14 S. R. No. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 1 3/4 acre

Character & Porosity of Soil clayey
Percolation Rate 30 min/1" fg. fill
Topography 2-6%
Depth to Water Table 4'+
Rock or other impervious formations scattered rock.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field: 3
No. of Lines _____
Sq. Ft. 1200+ Linear Ft. 400+
Depth of Stone in Lines 12"+
Water Supply: Individual ( )
Public (✓)

Installed by James Hudlow

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Kelly Sleeks R.S.

COMMENTS: All lines exceeded 133'+ had extra stone.

CERTIFICATE OF COMPLETION BY Steve Brown

EXISTING SYSTEM CHECKED BY: _____ DATE 1-3-86.

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE _____

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold