03571

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Greg Culler DATE 9-20-85 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Mock Mill Rd 2nd Entrance from Bulah Rd TL into Mock Mill Run at end on left S. R. No. _____

SUBDIVISION NAME Mock Mill Run LOT NO. 16 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1 1/2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	5 col / 55 1 / 60	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2+0 6+0	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10 ft	
			Rock or other impervious formations	none	

Lot Area 1.2 acres

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Kenneth Chaffin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 9-20-85

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold