04901

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR DARRELL ISENHOUR DATE 6-24-86 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION Mock mill Rd. - off Beulah Rd. - enter 1st st. on dext. - 4th lot on left. S. R. No. _____

SUBDIVISION NAME MOCK MILL RUN LOT NO. 49 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2-3	No. Bathrooms 1-2	Character & Porosity of Soil	Poor Suitable.
Garbage Disposal Unit	Yes ( ) No (✓)	Percolation Rate	5gal./sq. ft.
Auto. Dishwasher	Yes (✓) No ( )	Topography	2-6%
Auto. Wash. Machine	Yes (✓) No ( )	Depth to Water Table	12+
Site Suitable	Yes (✓) No ( )	Rock or other impervious formations	none observed.
Lot Area Ample			

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 720 Linear Ft 240
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Dennis Gallifer Terry Luttrell

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Terry L. Pierce

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brewer DATE 6-24-86.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold