03639

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR DAVID LEE WARREN DATE 9-25-85 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Mock mill rd. - off Beulah Church Rd. - 1/4 mi. on left - enter 1st street - 30 yards on left. S. R. No. _____

SUBDIVISION NAME MOCK MILL RUN LOT NO. 46 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil Prev. Suitable
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate 5 gal./sq. ft.
Auto. Wash. Machine	Yes (✓)	No ( )	Topography 2-6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table 10+

Lot Area 20,745 sq. ft. Rock or other impervious formations none impervious

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Ray + Keith Sanders

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown

EXISTING SYSTEM CHECKED BY: _____ DATE 9-25-85

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE _____

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold